A47481

MEMORANDUM

REFER		NOTED	
TO	DATE	BY	DATE
RETURN TO		FILE	

0036582

TO: Mr. Malcolm P. Levy, Chief, Planning & Construction - WTC
FROM: Louis A. Cavenna
DATE: February 26, 1969
SUBJECT: WORLD TRADE CENTER - CONTRACT WTC-113.00 - SPRAY ON FIRE PROOFING NORTH AND SOUTH TOWERS

REFERENCE:

COPY TO: Messrs. Kirk, Shelton, Operations Planning Division

The Operations Services Department has reviewed subject specifications and has the following comments to offer:

Inspection and Safety Division
Coordinator: Joseph Rand Ext. 8256

Specifications - General

1. It is required that the spray fiber material be listed by U.L.

2. It is required that the sprayed-on fire proofing should conform to the latest changes of the New York City Administrative Building Code as indicated in the November 15, 1968 rulings of the Board of Standards and Appeals (copy attached).

If there are any questions with regard to the above comments, please advise.

Louis A. Cavenna
Assistant to Director
Operations Services Department

TF/lap
Att.

PLAINTIFF'S EXHIBIT
PX-507